

شرکت ملی گاز ایران
شرکت گاز استان هرمزگاناعضاء بازدید کنندگان
پیشنهاداتسرپرست خرید
رئیس گروه خریدرئیس خریدهای داخلی
رئیس امور تعداد کات کالاتأیید کمیسیون معاملات
(خریدهای عمده)

الف - لطفاً پیشنهاد قطعی خود را برای انجام موضوع استعلام با مشخصات و مفاد زیر و برگ ضمیمه آن طبق دستورات پایین تکمیل و تسلیم نمایید.

۱- آیا اجناس ساخت ایران است یا خارج: (ستون ۶) ۲- تاریخ قطعی تحویل کالا (ستون ۷) تاریخ تحویل مورد نیاز شرکت ۳- بهای قطعی هر واحد جنس (ستون ۸) - تخفیف برای هر واحد (ستون ۹) - جمع قیمت پس از تخفیف هر قلم (ستون ۱۰)

۴- هزینه حمل و نقل بهمه (ستون ۱۱) - ۸- هزینه حمل و نقل بهمه (ستون ۱۲) - ۹- هزینه کل کالا (ستون ۱۳) بهای حمل به شرکت مسئول حمل خواهد بود. فرورونده مسئول حمل خواهد بود.

۶- قیمت کلیه اقلام (ستون ۱۱) - در صورت لزوم هزینه بسته بندی (ستون ۱۲) - ۸- هزینه حمل و نقل بهمه (ستون ۱۳) - ۹- هزینه کل کالا (ستون ۱۴) بهای حمل به شرکت مسئول حمل خواهد بود. فرورونده مسئول حمل خواهد بود.

ج- پیشنهاد تسلیمی شما می بایستی پس از دریافت برای مدت هفت روز کاری معتبر باشد و چنانچه مدت ذکر شده مقدور نیست حداکثر مدت اعتبار پیشنهاد خود را از تاریخ تسلیم پیشنهاد ذکر نمایید. روز. ۵- شرح کامل هر گونه انحراف و تقلبی در مشخصات و یا مقادیر داده شده اجناس در خواستی زیر و اطلاع دهید.

شرکت:

نشانی:

تلفن:

شماره استعلام: ۳۰۷۹۸۰۴۰۵۸

شرح و مشخصات کالا	واحد	تعداد	پسته بندی شود	خیر - بلی	ساختمان ایران	زودترین تاریخ تحویل - ۷	بها واحد	تخفیف	قیمت کالا پس از تخفیف
شاتاف ولو ۳ اینچ کلاس ۳۰۰ (طبق مشخصات فنی پیوست)	NO	1							
شاتاف ولو ۴ اینچ کلاس ۳۰۰ (طبق مشخصات فنی پیوست)	NO	2							
شاتاف ولو ۴ اینچ کلاس ۶۰۰ (طبق مشخصات فنی پیوست)	NO	3							
شاتاف ولو ۶ اینچ کلاس ۳۰۰ (طبق مشخصات فنی پیوست)	NO	1							
شاتاف ولو ۶ اینچ کلاس ۶۰۰ (طبق مشخصات فنی پیوست)	NO	2							
شاتاف ولو ۸ اینچ کلاس ۶۰۰ (طبق مشخصات فنی پیوست)	NO	1							
کالاهای درخواستی بایستی دارای یک سال گارانتی و ده سال خدمات پس از فروش باشند.									

سه برگ مشخصات فنی پیوست می باشد. فروشندگان بایستی پیشنهادات مالی و فنی را بصورت جداگانه پیوست نیاز نمایند در صورت عدم بارگذاری پیشنهادات بصورت جداگانه پیشنهاد فروشندگان رد می گردد و حق هیچگونه اعتراضی نمی باشد.

خرید از تولید کنندگان تأیید شده وندور لیست وزارت نفت صورت می پذیرد. هزینه هر گونه تست، بازرسی و حمل تا درب انبار شرکت گاز استان هرمزگان به عهده فروشنده می باشد.

۱۱- قیمت کالا	پس از تحویل کالا واریه صورت حساب مودیان ثبت شده در سامانه مالی در مهلت حداکثر ۲ ماهه مطابق ضوابط و مقررات ملی شرکت گاز استان هرمزگان پرداخت صورت می پذیرد.
۱۲- هزینه بسته بندی	۱- رونوشت استعلام چهار از طریق سر بسته راک و مهر شده حداکثر تا تاریخ ارسال گردد. به پیشنهادت واصله و یا تجدید نظر شده پس از تاریخ مقرر ترتیب اثر داده نخواهد شد. شرکت حق خواهد داشت تا ۲۵٪
۱۳- هزینه حمل و نقل بهمه	۲- شرکت مختار است یک تا چند قلم و یا تمام اقلام را بر اساس پیشنهاد رسیده تکنیک و معامله و انجام دهد و در ضمن شرکت در رد و یا قبول یک یا کلیه پیشنهادات بدون ذکر دلیل مختار است. ۴- بایستیم پیشنهاد خود متعهد به انجام شرایط قرارداد مندرج این ورقه می باشد.
۱۴- هزینه کل کالا	۵- شرایط کلی قرارداد مندرج در تبصره ۳ مربوط به تودیع سپرده تعلق میگیرد. نمیگیرد و مقدار سپرده معادل٪ از قیمت استعلام بها خواهد بود.
	۶- در مورد تأخیر و تحویل برای هر روز از مبلغ تضمین حسن انجام کار و در صورتی که تکاوت ننماید از سپرده نقدی و یا هر نوع مطالبات دیگر کسر خواهد شد.
	۷- شماره استعلام بهای فوق باید در تمام مکاتبات با این شرکت قید گردد.
	آدرس: بندر عباس - بولوار دانشگاه - بلوار گاز - شهر فجر - شرکت گاز استان هرمزگان - تلفن: ۰۹۳۳۱۸۳۵۲۵۸ - ۰۷۶۳۱۹۴۷۲۰۱
	امضاء کننده کلیه شرایط فوق را قبول نموده و اجرا می نماید
	محل امضاء فروشنده و یا نماینده ایشان
	مدت اعتبار قیمت پیشنهادی:
	قل از صلیحه قبل
	هزینه مجموع

از مبلغ پیشنهادی به فروشنده پرداخت نمی گردد.

ردیف	نوع تجهیز	نام و نام خانوادگی	شرح تجهیز
۱	شات آف ولو	Zauner	Valve Type: Trunnion Ball Valve, Max Operating Pressure 102 bar, Operating Temperature: (-20 +60)C, Regulator Set at: 3 bar, Control type: SSV-HP-DA-04, Shutoff Set point: 300 psi, Min. Pilot setting: 280 psi, Max. Pilot setting: 310 psi, Max work Pressure: 1440 psi
۲	شات آف ولو		Valve Type: Trunnion Ball Valve, Max Operating Pressure 102 bar, Operating Temperature: (-20 +60)C, Regulator Set at: 3 bar, Control type: SSV-HP-DA-04, Shutoff Set point: 300 psi, Min. Pilot setting: 280 psi, Max. Pilot setting: 310 psi, Max work Pressure: 1440 psi
۳	شات آف ولو	Arvin andozan save	Max. Allowable Working Pressure: 740 psi, Max. Operating Pressure: 250 psi, Min. Operating Pressure: 150 psi, Shutoff Over Pressure Range: 15-150 psi, Shutoff Under Pressure (Rising) Set point: 72 psi, Shutoff Under Pressure Range: 15-150 psi, Shutoff Under Pressure (falling) Set point: 15 psi, Inlet Connection Size: 1/2 inch, Outlet Connection Size: 1/4 inch
۴	شات آف ولو		Max. Allowable Working Pressure: 740 psi, Max. Operating Pressure: 250 psi, Min. Operating Pressure: 150 psi, Shutoff Over Pressure Range: 15-150 psi, Shutoff Under Pressure (Rising) Set point: 72 psi, Shutoff Under Pressure Range: 15-150 psi, Shutoff Under Pressure (falling) Set point: 15 psi, Inlet Connection Size: 1/2 inch, Outlet Connection Size: 1/4 inch
۵	شات آف ولو	Cortball	Series: PP - A SERIAL NO. GB 22380 Max. Working Pressure: 1050 psig Min. Working Pressure: 400 psig Pressure range: 15 - 600 psig Shut off Pressure set Point: 350 psig rising Inlet connection size: 1/2" Npt Outlet connection size: 1/2" Npt Ansi class rating: 6000 Lb valve design: Api 6D valve size: 6" Body: carbon steel astm a 105 Ball: Enp carbon steel astm a 105 Seat rings: Enp carbon steel astm a 105 Stem/trunnion: Enp alloy steel a151 4140 Seats: Ptf
۶	شات آف ولو	Ball valve-pietro fiorentini	Line off device type: 103N-P S.n: 2000za0945 Pemax: 1232 psig Tripping unit type: 103n T: -10 +60C Who: 40-137psig Wao: 40-80 psig Ag:5
۷	شات آف ولو	Vastas	Figure: E630GS. 118, Valve Design Standard API6D, Valve Pressure Rating: 0-100 bar, Valve Temperature Rating: (-29 to +100 C), Control Type: GSLH, Actuator Type: GS72, Shutoff Set High Pressure: 300 psi, Actuator Temperature Rating: (-28 to +80 C), Shutoff Pressure Rating: 10-100 bar, Mounting Flange: ISO F10/F12, Shell Test: 153 bar
۸	شات آف ولو	گازسوزان	
۹	شات آف ولو	پترو گاز پارس	
۱۰	شات آف ولو	Zauner	
۱۱	شات آف ولو	Pishgaman	Model: PEK105, Max. Working Pressure: 1480 psi, Min. Working Pressure: 140 psi, Valve Design: API 6D, High Pressure Set: 350-1240 psi, Low Pressure Set: 240-730 psi, High Operating Range: 900-1240 psi, Low Operating Range: 240-730 psi, Operating Temperature: (-29 to +60), Pneumatic Actuator Type: PD6, Feeding Pressure:

1. GENERAL INFORMATION					
1.1	Project Name	Hormozgan Gas Project – CGS & TBS (HPGC 2025)			
1.2	Location	Bandar Abbas, Iran			
1.3	Equipment Tag No.	SOV-XXX(SOV-CGS-2xA-1xB Run-2 Active)			
1.4	Procurement Specification	N.I.G.C.			
1.5	Station Type	TBS 5,000 SCMH (Flat-Type, 2-Run)			
1.6	Quantity Required	2 Set			
1.7	Manufacturer	[Vendor to propose]			
1.8	Model / Series	[Vendor to propose]			
1.9	Product No.	[Vendor to propose]			
1.10	Quotation No. / Date	[Vendor to propose]			

2. SERVICE & DESIGN CONDITIONS					
No.	Parameter	Description	Unit	Standard	Remarks
2.1	Type of fluid handled by the valve	Natural Gas	-	-	-
2.2	Relative density of the fluid	0.65	-	-	-
2.3	Normal operating pressure downstream	60	psig	-	-
2.4	Range for overpressure trip setting	66-78	psig	-	-
2.5	closes on overpressure	72	psig	-	-
2.6	closes on underpressure	45	psig	-	-
2.7	Gas temperature range	MIN(-10) MAX(+60)	°C	-	-
2.8	Maximum Allowable Working Pressure	740	psig	ASME B16.34	ASME B16.34 Class 300
2.9	Minimum and Maximum Design Temperature	MIN(-10) MAX(+60)	°C	-	-
2.10	Conformance to fire safe standards	Yes	-	API 6FA	-

3. TO BE FILLED BY SUPPLIER					
No.	Parameter	Description	Unit	Standard	Remarks
3.1	Maximum time for valve to fully close/open	5	seconds	-	Close time (full stroke): ≤5 s
3.2	Location of installation	Outdoor	-	-	-
3.3	Maximum ambient temperature	60	°C	-	-
3.4	Minimum ambient temperature	0	°C	-	-
3.5	Maximum relative humidity	90	%	-	-

4. MECHANICAL DESIGN & CONSTRUCTION					
No.	Parameter	Description	Unit	Standard	Remarks
4.1	Valve Type	Ball, Trunnion, Full Bore-Actuated	-	ASME B16.34 / B16.5	Quick Closing & Slow Opening
4.3	Nominal pipe size of the valve	4"	Inch	-	-
4.4	Pressure rating of the valve	300#	-	ASME B16.34	-
4.5	Inlet/Outlet Connection Type	Flanged Ends	-	ANSI B16.5	-
4.6	Pressure rating of flanges	ANSI Class 300	-	ASME B16.5	-
4.7	Flange facing type	Raised Face, Serrated Finish	-	-	-
4.8	Actual bore size of inlet/outlet	4.02"	Inch	-	-
4.10	Type of actuator	Single Acting Pneumatic Actuator, Power-to-Open and Close	-	-	Manual-Resettable Latching
4.11	High trip pressure setting	375	psig	-	-
4.12	Low trip pressure setting	250	psig	-	-
5. MATERIALS OF CONSTRUCTION					
No.	Parameter	Description	Unit	Standard	Remarks
5.1	Material of valve body	ASTM A105 / A216 WCB	-	-	-
5.2	Material of valve ball	ASTM A105	-	-	-
5.3	Material of valve stem	ASTM A105	-	-	-
5.4	Material of O-Rings	HNBR/PTFE	-	-	-
6. DOCUMENTATION & TESTING					
No.	Parameter	Description	Unit	Standard	Remarks
6.1	List of documents required	1 Sets	-	-	GA, P&ID hook-ups, IOM, QAP, Certs, Spare List
6.2	Non-Destructive Testing (e.g., RT, UT, MT, PT)	VT/PT	-	ASME Sec. VIII, Div. 1	Based on project specifications
6.3	Pressure for hydrostatic test	1.5×MAWP	psig	-	e.g., 1.5 x MAWP

Functional Note:

Valve is pneumatically operated (spring-return type). On trip (over/under pressure), valve closes automatically and remains latched until manually reset. In case of power or air failure without trip, valve retains last position. Both upstream and downstream sensing lines are included for over/under-pressure detection.

SOV sensing arrangement and trip logic are in accordance with EN 12186 and N.I.G.C. Gas Pressure Regulation Station Specification.